
# Product data sheet Automation Technology



Product description

Polzahl: 4, Kabeldurchlass: 6 - 8 mm, Kabelstecker, schirmbar, CAT 5 Schraubklemmanschluss, Schirmringversion, mit UL-Zulassung

Area Order number M12-D, M12-X Series 825 D-Kodierung 99 3729 810 04





# You can find the component part drawing and assembly instructions on the next page.

**Technical data** 

#### **General values**

Connector design Connector locking system Termination Wire gauge (mm) Wire gauge (AWG) Cable outlet Upper limit temperature Lower limit temperature

### **Cable data**

Approval 1

Cable Connector bolted screw 0,75 mm<sup>2</sup> (18) 6 – 8 mm 85 °C -40 °C

UL

## **Electrical values**

Rated voltage Rated impulse voltage Pollution degree Overvoltage category Insulating material group Rated current (40 °C) Volume resistivity EMC compliance Degree of protection Mechanical operation

### Material

Contact material Contact plating Contact body material 250 V 2500 V 3 II III 4 A  $\leq$  3 m $\Omega$ shieldable IP67 > 100 Mating cycles

CuZn (Messing) Au (gold) PA




# Product data sheet Automation Technology




Product description

Polzahl: 4, Kabeldurchlass: 6 - 8 mm, Kabelstecker, schirmbar, CAT 5 Schraubklemmanschluss, Schirmringversion, mit UL-Zulassung

Area Order number M12-D, M12-X Series 825 D-Kodierung 99 3729 810 04







# Product data sheet Automation Technology



Product description

Polzahl: 4, Kabeldurchlass: 6 - 8 mm, Kabelstecker, schirmbar, CAT 5 Schraubklemmanschluss, Schirmringversion, mit UL-Zulassung

 Area
 M12-D, M12-X

 Order number
 99 3729 810 04

M12-D, M12-X Series 825 D-Kodierung 99 3729 810 04

## Sicherheitshinweise

- 1. The connector must not be connected or separated under load. Non-observance and incorrect use can result in personal injury.
- 2. The connectors are designed for use in plant, control system and electrical equipment. The end user is responsible for checking whether the connectors are suitable for use in other applications.
- 3. To prevent the connector being opened unintentionally when used in electrical circuits containing hazardous life parts, the thread between the housing and the connector head must be secured using a suitable cyanoacrylate adhesive. This does not apply to connectors used in SELV and PELV circuits according to IEC 61140 (EN 61140, VDE 0140-1).
- 4. Connectors used in electrical circuits containing hazardous life parts must only be assembled and used by or under the supervision of persons with the requisite electrotechnical training, taking the applicable regulations and standards into account.
- 6. Connectors with degree of protection IP 67 and IP 68 are not suitable for use under water. When used outdoors, the connectors must be separately protected against corrosion. For further information about IP degrees of protection refer to 'Technical support' in the Download Centre.
- 8. To lock the cable connector to the equipment connector, the threaded ring is tightened until it is 'finger-tight' (approx. 50 cNm).

